

## Type 3 Swimming Pool – Compliance Checklist

### A. Water Quality & Monitoring (Mandatory)

- ☐ **pH 7.20–8.00** (tested at least 3× daily)
- ☐ **Free chlorine** within required levels (checked morning, midday, afternoon; one test at peak use)
- ☐ **Water clarity:** Secchi disc visible at 10 m
- ☐ **Total alkalinity** 80–120 mg/L
- ☐ **Continuous water renewal** during operation
- ☐ **Full renewal within required time** (existing pools: ≤4 hours)
- ☐ **Monthly microbiological testing** by accredited lab
- ☐ If microbiological limits exceeded → **take corrective action & notify competent authority**

### B. Recirculation & Filtration System (Mandatory)

- ☐ Recirculation system runs during entire operation
- ☐ Pumps (active + standby 50% capacity)
- ☐ Filters meet required filtration rate
- ☐ Flow meters and pressure gauges installed and accessible
- ☐ Annual hydraulic performance test by Mechanical Engineer
- ☐ Proper backwashing procedures followed and recorded

### C. Disinfection & Chemicals (Mandatory)

- ☐ Continuous disinfection (chlorine or approved alternative)
- ☐ Cyanuric acid ≤100 mg/L (if used)
- ☐ Disinfection records logged daily (Second Schedule format)
- ☐ Chemicals stored in **dry, ventilated, separate area**
- ☐ Automatic dosing recommended (mandatory if >200 m<sup>3</sup>)

### D. Responsible Pool Operator (Mandatory)

- ☐ Operator appointed in writing (Third Schedule form)
- ☐ Minimum qualifications: age ≥21, secondary education, clean criminal record
- ☐ First aid + health certificate (optional for Type 3)
- ☐ Operator duties performed:
  - ☐ Monitoring chlorine & pH
  - ☐ Conducting/arranging testing
  - ☐ Maintaining logbook
  - ☐ Ensuring safe operation & signage
  - ☐ Monitoring bather numbers

### E. Cleanliness & Hygiene (Mandatory if facilities exist)

- ☐ Pool kept clean; debris removed daily
- ☐ Changing rooms, toilets, showers (if present) kept clean and disinfected

- ☐ Insecticide used in cloakrooms (if present)
- ☐ Operation suspended if hygiene risk identified

**F. Safety Requirements (Mandatory Minimum for Type 3)**

- ☐ Safety rules and hygiene instructions posted clearly
- ☐ At least one **rescue pole** ( $>\frac{1}{2}$  pool width)
- ☐ At least one **life ring with rope** per 60 m pool perimeter
- ☐ Fully equipped **first-aid kit** available
- ☐ Emergency contact list displayed (doctor, hospital, police, fire, 112)

**Optional but recommended for Type 3:**

- ☐ Spinal board
- ☐ Bag-valve mask (BVM)

**G. Bather Rules (Mandatory)**

- ☐ Bather obligations (Fourth Schedule) displayed in Greek & English
- ☐ Noncompliant persons denied entry or removed
- ☐ SPA / hydrotherapy rules posted if applicable

**H. Maximum Number of Bathers (Mandatory)**

- ☐ Maximum bather load calculated as per Seventh Table in the regulations
- ☐ Manual counting system in use to prevent overcrowding